

Electrical Safety Certification Practice Test Questions and Answers

1. What is the minimum safe approach distance for qualified workers working on energized 480V equipment?

- A) 1 foot
- B) 3 feet 6 inches
- C) 6 feet
- D) 10 feet

2. Which OSHA standard specifically covers electrical safety in the workplace?

- A) 29 CFR 1926.95
- B) 29 CFR 1910.269 and 29 CFR 1910.331-335
- C) 29 CFR 1915.82
- D) 29 CFR 1928.57

3. What does LOTO stand for in electrical safety procedures?

- A) Low Output Testing Only
- B) Lockout/Tagout
- C) Limited Operations Technical Order
- D) Load Operation Test Override

4. Which type of PPE is required for arc flash protection?

- A) Regular cotton clothing
- B) Arc-rated clothing, face shields, insulated gloves, and safety glasses
- C) Leather gloves only
- D) Standard work uniforms

Answers: 1-B 2-B 3-B 4-B

For More Electrical Safety Certification Questions and Answers FREE, Electrical Safety Certification Online Prep Training, Electrical Safety Certification Exam, Electrical Safety Certification Study Guide, Electrical Safety Certification Flashcards, Electrical Safety Certification Quizzes visit:

Electrical Safety Certification Practice Test

Practice Test Geeks © All Rights Reserved