

Licensed Electrical Contractor Practice Test Questions and Answers

1. What is the minimum wire size for a 20-amp branch circuit according to NEC?

- A) 14 AWG
- B) 12 AWG
- C) 10 AWG
- D) 8 AWG

2. What does GFCI stand for in electrical safety?

- A) Ground Fault Circuit Interrupter
- B) General Fault Current Indicator
- C) Grounded Function Control Interface
- D) Ground Field Connection Isolator

3. What is the maximum voltage drop allowed for branch circuits under NEC?

- A) 3%
- B) 5%
- C) 8%
- D) 10%

4. Which electrical permit is typically required before starting electrical work?

- A) Building permit only
- B) Electrical permit from the local authority having jurisdiction
- C) State contractor license only
- D) No permits are required

Answers: 1-B 2-A 3-B 4-B

For More Licensed Electrical Contractor Questions and Answers FREE, Licensed Electrical Contractor Online Prep Training, Licensed Electrical Contractor Exam, Licensed Electrical Contractor Study Guide, Licensed Electrical Contractor Flashcards, Licensed Electrical Contractor Quizzes visit:

Licensed Electrical Contractor Practice Test

Practice Test Geeks © All Rights Reserved